

# CERTIFICATE OF CONFORMITY


with

**IEC61000-4-30 :2003 Class A Testing and Measurement Techniques -  
Power Quality Measurement Methods**

<b>Certificate No:</b>	TI/132/8407
<b>Manufacturer:</b>	<b>Dranetz-BMI</b> 1000 New Durham Road Edison, NJ 08818-4019 USA

<b>Product Type:</b>	<b>Power Quality Measurement Instruments</b>		
<b>Model No:</b>	<b>Model PX5 Power Xplorer and variant models: PX5-400 Power Xplorer, 4400 Power Guide, 440S Power Guia &amp; 440J Power Visa.</b>		
<b>Report Ref:</b>	61000-4-30 Technical Construction File – electronic version Document Number DTI-PQ-TC1	<b>Date Created</b>	7 <sup>th</sup> December 2004
	Amendment 1	<b>Date Created</b>	5 <sup>th</sup> January 2005

In our capacity as an independent product safety consulting firm, and an EU Competent Body for the EMC Directive and Notified Body for the Low Voltage Directive, from the evidence of an examination of the above report, we hereby certify that the product described above complies with the requirements of IEC 61000-4-30:2003 Class A Testing and Measurement Techniques - Power Quality Measurement Methods.

<b>Issued By:</b>	<b>Technology International (Europe) Limited</b> 60 Shrivenham Hundred Business Park Shrivenham, Swindon, SN6 8TY Tel: (+44) 1793 783137 Fax: (+44) 1793 782310	
<b>Signed:</b>		
<b>Name:</b>	<b>A.L. Brown</b> <i>BSc, MSc, CPhys, MInstP</i>	<b>Date:</b> 13 <sup>th</sup> January 2005